

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204442
Address: 2009 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Thursday, September 23, 2021

Corrective Action Required:

1	Miscellaneous Correction	Lower water meter lid to grade-14" to 18" from top of meter to top of can required AS WELL AS LID BEING AT GRADE-NOT COMPLETE
---	--------------------------	---

Comments: