CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213588

Address: 3703 SW WALSH DR, LEES SUMMIT, MO 640823705 SW WALSH DR, LEES SUMMIT, MO 640823707

SW WALSH DR, LEES SUMMIT, MO 640823701 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Footing Inspection - Residential Patrick Schonfeldt Failed Friday, September 24,

2021

Corrective Action Required:

1 Misc THIRD PARTY ENGINEER REPORT REJECTED, INFORMATION INCOMPLETE,

REQUIRED TO NOTE LOCATIONS OF UFER GROUNDS ON INSPECTION REPORT

IN NOTES

Comments: