

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210367
Address: 2108 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|-----------|----------------------------|
| Occupancy Inspection - Codes Residential | Michael Harkins | Not Ready | Friday, September 24, 2021 |

Corrective Action Required:

| | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | Driveway inspection pending Raise manhole cover to grade Lower water meter lid to grade Provide handle & secondary lock SGD Seal exterior light fixtures |
|---|--------------------------|--|

Comments: