

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211915
Address: 2366 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Friday, September 24, 2021

Corrective Action Required:

1	Misc	-Maintain silt fence and clean silt and debris storm inlet -Nail protection plates at NM garage less than 1 1/4" from end of stud -(4) 1 3/4" x 9 1/4" LVL joists at garage (2) locations per plans
---	------	---

**OK to insulate

Comments: