

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214745
Address: 130 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Michael Harkins	Passed	Friday, September 24, 2021

Informational:
1 Misc UFER LOCATED NORTH BASEMENT FOUNDATION WALL ABOUT 4' FROM FRONT OF HOUSE

(3) 36 X 36 X 18 PADS FORMED UP AT DECK PIERS
PLANS CALL FOR (2) J 18 X 36 & (1)K 24 X 36
36" DEEP CONCRETE PIER INTO UNDISTURBED ORIGINAL SOIL

Comments: