

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204535
Address: 2029 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Adam Nacke	Failed	Friday, September 24, 2021

Corrective Action Required:

1 Misc No aggregate in place

Informational:

2 Misc Forms were placed and aggregate was present and compacted. Notified Summit Homes about broken mailbox pad. RP 9-17-21

Informational:

3 Misc 9-24-21 11:50. Sidewalk is good and meets ADA spec of 1.5% or less. Expansion joint on east side of house snagged my foot and needs to be cut.

Comments: