

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210157  
Address: 2033 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Adam Nacke	Passed	Friday, September 24, 2021

Corrective Action Required:

1	Misc	No aggregate in place.
Informational:		
2	Misc	Forms were placed and aggregate was present and compacted. RP 9-17-21
Informational:		
3	Misc	Sidewalk is good and meets ADA spec of 1.5% or less

**Comments:**