

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211217
Address: 2101 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Adam Nacke	Passed	Friday, September 24, 2021

Informational:	
1 Misc	Forms are in place and rock is present and compacted. Right of way is in ADA spec.

Informational:	
2 Misc	Driveway is good and meets ADA spec

Comments: