



PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRPWRW20213580, Public Works Right of Way Permit
Address: 4541 NE SENECA TER, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit Inspection	Matt Munger	Passed	Monday, September 27, 2021

Corrective Action Required

1 Misc

Site Visit - The service line has been installed. This is a new home build, the yard was not established prior to Spires work. The lot across the street is vacant and is not established either. According to the depths marked on the street, they didn't meet the 36" requirement. The road isn't humped or damaged. I took a picture of the depths that are marked on the street and uploaded into the documents in the event a street failure occurs at this location.

Comments: