

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200719
Address: 342 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Monday, September 27, 2021

Corrective Action Required:

1	Miscellaneous Correction	Provide splash blocks Paint exterior gas lines Provide clamp at AC Whip Seal top of meter can, exterior light fixtures Fire caulk upward penetrations pool pump room & mechanical room Provide GFCI protection between counter & patio door Submit back flow certification lawn irrigation & building Return slide handrails to post or walking surface & extend not less than 12" past top riser & continue to slope for the depth of one tread beyond bottom riser
---	--------------------------	---

Comments: