

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210882
Address: 202 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------|------------|----------|----------------------------|
| Sidewalk Inspection | Adam Nacke | Passed | Monday, September 27, 2021 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | Aggregate was no compacted. |
| 2 | Misc | Forms were placed and aggregate was present and compacted. RP 9-17-21 |
| 3 | Misc | Sidewalk looks good and meets all ADA specs |

Comments: