

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20210481

Address: 2550 SW 3RD ST, LEES SUMMIT, MO 64081141 NW MORTON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water - Material Verification	Ronald Paynter	Failed	Tuesday, September 28, 2021

Informational:

1	Misc	Only materials delivered so far is 8 inch C-900 water pipe from Sanderson. RP 5-11-21
---	------	---

Corrective Action Required:

2	Misc	Fire hydrants have the wrong fitting at the base. Jarrod had the supplier send of the spec sheet concerning the fitting. Forwarded this on to water, who promptly rejected the fitting as not meeting our spec. I notified the contractor with Water's findings. RP 9-28-21
---	------	---

Comments: