

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211218
Address: 127 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Tuesday, September 28, 2021

Corrective Action Required:

1	Miscellaneous Correction	Nail studs at intersecting wall corners per code/plan sheet S1.0 #9 (Kitchen) Insulate behind tub/shower enclosures on exterior walls Provide HUS26 hangers Bed 2 (one hanger is HUS24) Provide Boca plate master vanity (boca shall extend 2" above sole plate) Provide 1" clearance single wall vent at furnace (not done) Insulate & solid block cantilever per plan above service panel
---	--------------------------	--

Comments: