

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211584
Address: 2134 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Tuesday, September 28, 2021

Informational:

1	Misc	-7/12/21 OK TO COVER GARAGE PORTAL AND COVERED PORCH
---	------	------------------------------------------------------

Corrective Action Required:

3	Miscellaneous Correction	Provide mid point support vertical DWV 2" & Fire block & seal both dead spaces in great room (near SGD HVAC & DWV)
---	--------------------------	-------------------------------------------------------------------------------------------------------------------------

Fire block / insulate DWV bath # 4 /garage
(missed one near mud room)
Address notched joist bath #4
Nail studs at intersecting wall corners per code
Double every other joist per plan garage chase at 20 min door
Nail off joist hanger at LVL near stairs
Address triple floor joist at missing cantilever under fireplace
Nail exterior wall sheathing per code

Comments:

