

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211961  
Address: 1523 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Tuesday, September 28, 2021

Corrective Action Required:

1	Misc	-CS-PF bracing design per plans at breakfast sgd, detail A4 in plans -nail exterior sheathing per plans -Nail all exterior sheathing per plans WSP, 8D nails 6" edge, 12" field, no staples -Revise and submit plans, plot plan to include covered deck, no pier inspection performed, submit engineer letter
---	------	---

OK TO INSULATE & ROCK

**Comments:**