

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20200719
Address: 342 NW AMBERSHAM DR, LEES SUMMIT, MO 64081
Inspected On: Tuesday, September 28, 2021
Inspected By: Michael Harkins
Expiration Date: 10/28/21

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Temporary C of O	Tuesday, September 28, 2021

Corrective Action Required:

- | | | |
|---|-----------------------------|--|
| 1 | Miscellaneous
Correction | Paint exterior gas lines
Provide clamp at AC Whip
Seal top of meter can, exterior light fixtures
Fire caulk upward penetrations pool pump room & mechanical room
Submit back flow certification lawn irrigation & building
Return slide handrails to post or walking surface & extend not less than 12" past top riser & continue to slope for the depth of one tread beyond bottom riser |
|---|-----------------------------|--|