

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211893
Address: 103 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, September 28, 2021

Informational:

1	Misc	: PFH GARAGE PORTAL FRAMING ONLY : OK TO COVER
---	------	---

Corrective Action Required:

2	Misc	2ND TRIP ALL ROUGH PORCH & PATIO ONLY OK TO COVER PORCH & PATIO
---	------	---

Corrective Action Required:

3	Miscellaneous Correction	Seal upward penetration bed 2 closet Anchor bolts garage shall be in middle 1/3 the width of plate Tighten 5/8 anchor bolts garage portal Tighten anchor bolts garage Provide anchor bolt single car garage Seal upward penetration kitchen Seal fire block dead space bed # 5 Provide anchor bolts SCH 40 columns basement All wall outlets at garage to be 20 amp
---	-----------------------------	---

Comments: