

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212483
Address: 2114 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, September 29, 2021

Corrective Action Required:

1	Miscellaneous Correction	PFH GARAGE PORTAL FRAME ONLY TIGHTEN 5/8 ANCHOR BOLTS SOLID BLOCK & NAIL SHEATHING BREAKS ABOVE OVERHEAD DOOR NO TRUSS PLANS ON SITE LEAVE PORCH & PATIO EXPOSED FOR ALL ROUGH INSPECTION
---	-----------------------------	--

Comments: