

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20202008  
Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Air Test</b>	Adam Nacke	Partial	Wednesday, September 29, 2021

Corrective Action Required:

1	Misc	9-27-21 8:00 AN Pressure test 4psi between 10min and 7:30min
		MH 9-4 to 3-1 passed.      MH 2-2 to 2-1 passed
		MH 3-1 to 3-2 passed.      MH 2-1 to 1-2 passed
		MH 3-2 to 3-3 passed.      MH 2-3 to 2-2 passed
		MH 1-6 to 1-5 passed.      MH 4-5 to 4-4 passed
		MH 1-5 to 1-4 passed.      MH 4-4 to 4-3 FAILED start for 30days is 9-27-21
		MH 1-4 to 1-3 passed.      MH 4-3 to 4-2 passed
		MH 1-3 to 1-2 passed.      MH 4-2 to 4-1 passed
		MH 1-2 to 1-1 passed.      MH 4-1 to EX MH 2 passed
		MH 1-1 to 1-0 passed

**Comments:**