CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20200776

Address: 114 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Public Curb InspectionJoe StarlinPartialTuesday, September

14, 2021

Informational:

1 Misc 9/14/21 Tuesday

Contractor began @ 4:00PM pouring curb along SE Main & SE 2nd St.

9/29/21 Wednesday

Contractor had to remove sidewalks and curbs at 2nd ST & Main ST on 9/27/21 because lack of compliance. Curbs were installed to drain toward storm box .

Additional changes may need to occur to through and storm box.

Comments: