

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20213627  
Address: 1165 NE RICE RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Failed	Wednesday, September 29, 2021

Corrective Action Required:

1	Misc	-Connect ducts to all ceiling registers -Secure and support all low voltage cables off ceiling grid -Secure all MC cables within 12" of j-box -Repair broken fresh air duct above east end of corridor -Color tag/label all MC supporting wirings
---	------	---

Comments: