

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20210481

Address: 2550 SW 3RD ST, LEES SUMMIT, MO 64081141 NW MORTON DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water - Material Verification</b>	Ronald Paynter	Passed	Wednesday, September 29, 2021

Informational:

1	Misc	Only materials delivered so far is 8 inch C-900 water pipe from Sanderson. RP 5-11-21
---	------	---

Corrective Action Required:

2	Misc	Fire hydrants have the wrong fitting at the base. Jarrod had the supplier send of the spec sheet concerning the fitting. Forwarded this on to water, who promptly rejected the fitting as not meeting our spec. I notified the contractor with Water's findings. RP 9-28-21
---	------	---

Informational:

3	Misc	Water department agreed to let them use the Mueller fire hydrants with the white boot on the bottom. RP 9-29-21
---	------	---

**Comments:**