

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211620
Address: 2329 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Robb Popp	Failed	Thursday, September 30, 2021

Corrective Action Required:

1	Misc	-(3) 18x36 piers required per plan-missing middle pier-OK to pour (2) outside piers
---	------	---

Comments: