

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211027
Address: 2346 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Not Ready	Thursday, September 30, 2021

Informational:

1 Misc

****7/16/21 - GARAGE PORTAL EXTERIOR OK TO COVER****

Corrective Action Required:

2 Miscellaneous
Correction

-Fireblock top of chase in garage-SEAL GAPS AND PENETRATIONS-NOT DONE,
SEE PEX AND GAS LINE
-4x4 parallam column between 1st and upper level per plans
-Rafter ties at rafters over living room/ full height wall-PROVIDE H2.5s OR
RAFTER TIES PER PLAN-NOT DONE
-(1) 14" LVL, (2) 12" LVL ridge beam per plan or clarify with engineer
-LIB per plan- missing CSPF at living room
-Soffit vents per code

Comments: