

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210054
Address: 206 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Thursday, September 30, 2021

Informational:

1 Misc

NOTE : HAMMER ARRESTORS IN WALL @ LAUNDRY ROOM

Corrective Action Required:

2 Miscellaneous
Correction

Obtain Irrigation permit & submit back flow certification
Provide sod & splash blocks
Seal top exterior light fixtures
Remove cover smoke detectors
Insulate or Sheetrock floor joist mech room basement
4" sphere shall not pass through deck rail near fire place
Sump shall discharge 36" from foundation
Provide through bolts deck beam to post connection

Comments: