

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20212196  
Address: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Air Test</b>	Adam Nacke	Passed	Thursday, September 30, 2021

Informational:	
1	Misc
	9-30-21 12:30 AN Pressure test 4psi for 7:30 min
	MH E-3 to E-2 passed
	MH E-2 to E-1 passed
	MH E-1 to EX MH passed
	MH D-2 to D-1 passed
	MH D-1 to C-1 passed

**Comments:**