

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20212196
Address: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	Adam Nacke	Passed	Thursday, September 30, 2021

Informational:

1	Misc	9-30-21 12:30 AN. Vacuum test 10psi for 3.5 min MH D-1 passed MH D-2 passed MH E-1 MH was hit and shifted fixed and passed MH E-2 passed MH E-3 passed
---	------	---

Comments: