

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210592
Address: 134 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------|------------|----------|--------------------------|
| Sidewalk Inspection | Adam Nacke | Passed | Friday, October 01, 2021 |

Informational:
1 Misc Forms are in places and aggregate is present and compacted. Had worker adjust the form to reach the 1.5% slope. Ready to concrete

Informational:
2 Misc Sidewalk looks good and meets all ADA specs

Comments: