

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211038
Address: 1529 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, October 01, 2021

Informational:	
1 Misc	-GARAGE PORTAL EXTERIOR OK TO COVER
Corrective Action Required:	
2 Misc	-Nail triple truss girder at front bedroom together per plans -seal all top plate penetrations -finished basement -Shim Jack studs at front door -CS-PF design per plans at great room/kitchen exterior wall per plans

Comments: