

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212838  
Address: 528 SE DAVID RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Suspended Slab Inspection</b>	Robb Popp	Failed	Friday, October 01, 2021

Corrective Action Required:

1	Misc	-All dowels to be 12" oc. -Provide min. 1.5" concrete cover at bottom of reinforcement throughout- see dowels resting on metal pan, etc. -Not all dowels are vertically embedded, see NE corner
---	------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**