

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211582
Address: 4417 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, October 01, 2021

Informational:

1 Misc

GARAGE PORTAL EXTERIOR OK TO COVER

Corrective Action Required:

2 Misc

- seal all top plate penetrations - hall bath
- Nail protection plate at stud for DWV laundry - see stud penetration
- H2.5 truss hold downs at front bedroom
- Exterior wall bracing per design at dining room windows
- Fireblock between top plate and framing throughout at finished basement, see north wall at bedroom above egress window
- Nail all exterior sheathing per plans

Comments: