

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Monday, September 20, 2021

To:

Property Owner: TOWNSEND SUMMIT LLC Email:

Applicant: ANDERSON ENGINEERING INC Email:

Engineer: ANDERSON ENGINEERING INC Email:

From: Mike Weisenborn, Project Manager

Re:

Application Number: PL2021307

Application Type: Commercial Final Development Plan

Application Name: Cooper's Hawk

Location: 540 NW CHIPMAN RD, LEES SUMMIT, MO 64086

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Approved: See below for any conditions of approval.

Required Corrections:

Planning Review	Victoria Nelson (816) 969-1605	Long Range Planner Victoria.Nelson@cityofls.net	No Comments
------------------------	-----------------------------------	--	-------------

Engineering Review	Sue Pyles, P.E. (816) 969-1245	Senior Staff Engineer Sue.Pyles@cityofls.net	Approved with Conditions
---------------------------	-----------------------------------	---	--------------------------

1. Private parking lots shall follow Article 8 of the Unified Development Ordinance for pavement thickness and base requirements.
2. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to coordinate a preconstruction meeting / conference with the assigned Field Engineering Inspector.
4. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.

Traffic Review	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
-----------------------	--------------------------------	--	-------------

Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	No Comments
------------------------------	------------------------------	---	-------------
