

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211038
Address: 1529 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, October 04, 2021

Informational:

1	Misc	-GARAGE PORTAL EXTERIOR OK TO COVER
---	------	-------------------------------------

Corrective Action Required:

2	Misc	-seal all top plate penetrations -see basement office wall -Shim Jack studs at front door
---	------	--

Comments: