

Shake Shack #1348 - PRCOM20210599 - Revisions

To: Joe Frogge
From: Christina Sandore, Bergmeyer
Date: 09/09/2021
Subject: Streets of West Pyror, Lot 2, Lee's Summit Shake Shack

To Plans Examiner,

Our project has made the revisions below after the receipt of our Building Permit approval. We are re-submitting the following package, Field Notice #3, for your review and update of our Building Permit approval.

Revised Drawing Lists:

Field Notice #5

T001
E101
E102
E601

Field Notice #4

T001
AS101
A150
A503
E100
E101
E120
E601
E620

Field Notice #3

T001	QF201
AS101	QF301
AS102	QF401
AS201	M101
A100	P101
A102	P120
A103	P901
A104	E100
A120	E101

A210	E102
A211	E120
A302	E601
A303	E620
A304	
A305	
A502	
A540	
A601	
QF101	

Addendum #2

T001	A302
S000	A303
S002	A304
S003	A305
S100	A501
S101	A503
S102	A504
S200	P001
S201	P101
S501	P120
S502	P150
A102	P901
A150	E100
A201	E601

Issued for Construction Set

T001	A510
S200	A540
A100	A603
A101	QF101
A102	M101
A104	M601
A105	M701
A120	M702
A210	M703
A211	M704
A302	M705
A303	P101
A304	P102
A305	P901
A402	E001
A403	E601
A501	E602
A502	E621
A503	E622
	E623

Field Notice #1

T001(Sheet List Updated)

F101 (Relocating FDC to match Civil drawings. FDP has already been approved.)

Field Notice #2

T001 (Sheet List Updated)

C-1 (Revisions to drive thru median, menu board locations and added curbside parking signage on bollards.)

AS101 (Revisions to drive thru median and added signage for curbside pickup.)

A120 (Revisions to security camera locations.)

A401 (Change to IT rack specification.)

E100 (Updated conduit and power connections for adjusted for menuboard locations. Added camera and conduit on menuboard per comments received. Added camera and conduit on clearance bar per comments received.)

E102 (Adjusted camera locations. Added camera locations on building exterior. Added additional wireless access points to building exterior.)

Field Notice #3

- | | | |
|-----|-------|---------------------------------------------------------------------------------------------------------------------------------------|
| 1. | T001 | Updated Sheet List |
| 2. | AS101 | Revised site plan and added details for updated design direction |
| 3. | AS102 | Added sheet to display for reference details under separate permit |
| 4. | S400 | Updated frost wall shelf elevations shown in typical and double wall details.
Elevation adjusted to match finished floor elevation |
| 5. | A100 | Revised dimension at column H4 to coordinate with structural |
| 6. | A102 | Updated wall dimensions at kitchen |
| 7. | A103 | Updated finish extents at kitchen |
| 8. | A104 | Revised furniture specifications |
| 9. | A120 | Updated ceiling finish and fixture spacing |
| 10. | A210 | Removed interior elevations which were no longer required |
| 11. | A211 | Revised interior elevations to coordinate with kitchen drawings |
| 12. | A302 | Revised wall sections to match structural |
| 13. | A303 | Revised wall sections to match structural |
| 14. | A304 | Revised wall sections to match structural |
| 15. | A305 | Revised wall sections to match structural |
| 16. | A502 | Revised typical wall base detail to match structural |
| 17. | A540 | Removed non-relevant details |
| 18. | A601 | Revised finish schedule |
| 19. | QF101 | Moved 124, added 127, added 141, added 143a, added 200, changed size of 179, changed model number 206 |
| 20. | QF201 | Moved 124, added 127, added 141, added 143a, added 200, changed size of 179, changed model number 206 |

- | | |
|-----------|------------------------------------------------------------------------------------------------------------------------|
| 21. QF301 | Moved 124, added 127, added 141, added 143a, added 200, changed size of 179, changed model number 206 |
| 22. QF401 | Moved 124, added 127, added 141, added 143a, added 200, changed size of 179, changed model number 206 |
| 23. M101 | Added note 13 |
| 24. P101 | Updated sanitary design for kitchen background changes
Updated grease waste and sanitary vents behind kitchen sinks |
| 25. P120 | Updated water design for kitchen background changes
Updated hot and cold water behind kitchen sinks |
| 26. P901 | Updated sanitary riser diagram for kitchen background changes
Updated water riser diagram for updates behind sinks |

Field Notice #4

- | | |
|----------|-----------------------------------------------------------------------------------------------------|
| 1. T001 | Updated Sheet List |
| 2. AS101 | Revised site plan and added details for updated design direction |
| 3. A150 | Added missing attic vent locations |
| 4. A503 | Revised canopy ceiling detail |
| 5. E100 | Added bollards and circuiting to plan |
| 6. E101 | Added junction box and circuit for FACP and added keyed note 29 |
| 7. E120 | Added load controller and circuiting for bollards on 2/E120 |
| 8. E601 | Updated panel schedules to include loads for bollards and FACP |
| 9. E620 | Added bollard spec to luminaire schedule and added load controller spec to load controller schedule |

Field Notice #5

- | | |
|---------|------------------------------------------------|
| 1. T001 | Updated Sheet List |
| 2. E101 | Revised to show additional POS near drive-thru |
| 3. E102 | Revised to show additional POS near drive-thru |
| 4. E601 | Revised to show additional POS near drive-thru |