

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20211914  
Address: 4801 NE FREEHOLD CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, October 05, 2021

Corrective Action Required:

1	Misc	-Nail exterior wall sheathing per code -Nail corner studs per code -Protect wiring running across joists and studding where within 6 ft of attic access -Anchor garage plate at front entry garage -Protect plumbing at master closet Install a floor receptacle at dining rail -Unblock return air at rear basement bedroom wall and pan off return air space from ceiling space
---	------	---

\*\*OK TO INSULATE

**Comments:**