

TO: City of Lee's Summit
From: A Bright Plumbing
Regards: Dye test for 3130 SW Blue Ribbon
Date: 10/04/2021

Please allow this letter to enter the construction file for the 3130 SW Blue Ribbon single-family home. During the construction process the ground rough plumbing was not inspected prior to the pouring of the concrete slab. In the absence of this inspection a dye test was requested by the Lee's Summit Building Inspections Department. The under-slab plumbing was installed per code and passed the dye test. If there are any questions regarding this, please contact Dale Richardson at 816-215-0730.

Sincerely,

Dale Richardson
A Bright Plumbing

A handwritten signature in black ink, appearing to read 'DR', with a long horizontal flourish extending to the right.