

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20202008
Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	Adam Nacke	Passed	Tuesday, October 05, 2021

Informational:

1	Misc	9-27-21 8:00 AM Vacuum test 10psi for 3.5 min
		MH 9-4 passed. MH 4-5 passed
		MH 3-1 passed. MH 4-4 passed
		MH 3-2 fixed and passed. MH 4-3 passed
		MH 3-3 passed. MH 4-2 passed
		MH 1-6 passed. MH 4-1 FAILED
		MH 1-5 passed
		MH 1-4 passed
		MH 1-3 passed
		MH 1-2 passed
		MH 1-1 passed
		MH 2-3 passed
		MH 2-2 passed
		MH 2-1 passed

Informational:

2	Misc	MH 4-1 fixed and passed
---	------	-------------------------

Comments: