



October 5, 2021

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Field Issue of OSB installation for engineered braced wall panel method for Lot #89 Manor at Stoney Creek – 4417 SW Alabaster Circle Lee's Summit, MO 64082 – Permit # PRRES20211582

This letter addresses the OSB installation for engineered bracing method in the dining room for Lot#89 Manor at Stoney Creek.

- It is structurally acceptable to install 15/32" thick OSB on engineered braced wall panels at dining room portal frame on interior.
- It is structurally acceptable to omit installing OSB over rim board.
- Install 8d nails at 6" for panel edges and 12" for field nailing pattern and blocking per plan.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a light blue horizontal line.

Bradley Huxol, PE

