

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213683  
Address: 4816 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Khanh Nguyen	Failed	Wednesday, October 06, 2021

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. INSTALL EROSION CONTROL ALONG THE STREET. CLEAN SILT OFF THE STREET  NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.
---	---------------------------------------	---

**Comments:**