

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20202008
Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	Ronald Paynter	Partial	Wednesday, October 06, 2021

Informational:

1 Misc

Proof roll passed except for one 10ft. Area by O'Brien. Installed a stretch of geo grid and added 6 " of type 5 rock. Trucks ran over it this morning and it was good to go , This proof roll was for chemical subgrade, will still need one for the rock.

Comments: