

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20213070
Address: 4817 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Pending	

Corrective Action Required

1	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. SILT FENCE TORN DOWN FOR SEWER AND WATER SHALL BE RE-ESTABLISHED. STREET SHALL BE CLEANED UP IMMEDIATELY
---	------------------------------------	--

****STOP-WORK ISSUED 10/6**

****NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION
CONTROL PROVIDED.**

Comments: