

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211582  
Address: 4417 SW ALABASTER CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Passed	Wednesday, October 06, 2021

Informational:	
1 Misc	GARAGE PORTAL EXTERIOR OK TO COVER
Corrective Action Required:	
2 Misc	-Exterior wall bracing per design at dining room windows

**Comments:**