

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191295  
Address: 807 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Planning</b>		Temporary C of O	Thursday, September 30, 2021

**Corrective Action Required:**

1	PARKING LOT. A minimum of 7 parking spaces are required to be striped to serve the building. At least one of the 7 parking spaces shall be an ADA van-accessible space with adjacent access aisle.
---	--

**Comments:**