

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20212855  
Address: 490 NW PRYOR RD, Unit:ES, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Michael Harkins	Pending	

Corrective Action Required:		
1	Miscellaneous Correction	GROUNDING CONDUCTORS SHALL BE WHITE OR GREY

**Comments:**