

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20210599  
Address: 2051 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Michael Harkins	Partial	Thursday, October 07, 2021

Corrective Action Required:	
1 THE FOLLOWING AREAS ARE APPROVED	HARD LIDS RESTROOMS & HALLWAY, PREP KITCHEN & KITCHEN OK TO DROP TILE. LEAVE HOOD AREA BEHIND COUNTER EXPOSED FOR GREASE DUCT WRAP

**Comments:**