

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20204900
Address: 1460 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Michael Harkins	Not Ready	Thursday, October 07, 2021

Informational:	
1 Misc	Light pole piers Ok to pour, except LP 1 and 2 not ready
Corrective Action Required:	
2 Miscellaneous Correction	TWO LIGHT POLE BASES FRONT PARKING LOT NOT DRILLED, NO REBAR, NO DRIVEN GROUND ROD Michael Harkins 10/07/2021 3:00 PM

Comments: