

DEVELOPMENT SERVICES

Residential Plan Review

October 07, 2021

PFEIFER HOMES INC
1550 SW MARKET ST STE 210
LEE'S SUMMIT, MO 64081
(816) 524-5245

Permit No: PRRES20215208
Plan Name:
Project Address: 209 NW AMBERSHAM DR, LEES SUMMIT, MO 64081
Parcel Number: 62240240500000000
Location: WOODSIDE RIDGE 1ST PLAT LOTS 1-143 & TRACTS A-H---LOT 118
Type of Work: NEW SINGLE FAMILY
Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY
Description: NEW HOUSE. FINISHED WALKOUT BASEMENT. ENGINEERED FLOOR SYSTEM - DEFERRED. COVERED DECK.

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

Plot Plan Review **Reviewed By: Andrea Sessler** **Rejected**

1. A as-graded plot plan per Section 7-160, Code of Ordinances, is required prior to occupancy.
2. All easements with dimensions must be provided on the plot plan.

SOUTH BACK CORNER HAS A 2'X8' U.E.

Residential Plan Review **Reviewed By: Andrea Sessler** **Approved**

1. Identify type of joist package or floor truss package (if used) complete with layouts, fastening details, blocking and bracing requirements and minimum sheathing.

Planning Review RES **Reviewed By: Victoria Nelson** **Approved**

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:			
Residential, Decks		210	
Residential, Finished basements		1535	
Residential, garage		648	
Residential, Living Area		1940	
Residential, Un-Finished basements		273	
Roofing Material		Number of Bathrooms	3.5
Number of Bedrooms	4	Number of Stories	1
Number of Living Units	1	Total Living Area	3475
Sewer Connection Fee	17		