

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213384
Address: 301 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Michael Harkins	Failed	Friday, October 08, 2021

Corrective Action Required:		
1	Miscellaneous Correction	PROVIDE 10' COPPER LINE METER TO PEX CONNECTION HOUSE TO METER PIT SIDE (ONLY 6')

Comments: