

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20212196
Address: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	Adam Nacke	Partial	Friday, October 08, 2021

Informational:	
1 Misc	10-8-21 10:40 AN Did proof roll after the Portland stabilization subgrade was completed. There were 4 problem areas and all 4 areas were dug up and fixed.

Comments: