

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211583  
Address: 1705 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Patrick Schonfeldt	Failed	Friday, October 08, 2021

Corrective Action Required:

1	Misc	GAS PRESSURE MUST MAINTAIN 10 PSI MIN FOR TEST
---	------	--

**Comments:**